



Product certificate K6075/07

Issued 2016-06-15
Replaces K6075/06
Page 1 of 3

Gate valves and butterfly valves

STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Product Certification, Kiwa declares that legitimate confidence exists that the products supplied by

Appendagefabriek Kolk B.V.

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline BRL-K602 "Valves and other fittings for drinking water transport and distribution systems" dated 01-02-2012.

which covers the requirements of

EN 1074-2: 2000 "Valves for water supply – Fitness for purpose requirements and appropriate verification tests – Part 2: Isolating valves".



Luc Leroy
Kiwa

Publication of the certificate is allowed.

Advice: consult www.kiwa.nl in order to ensure that this certificate is still valid.

Kiwa Nederland B.V.
Sir Winston Churchillaan 273
Postbus 70
2280 AB RIJSWIJK
The Netherlands

Tel. +31 88 998 44 00
Fax +31 88 998 44 20
info@kiwa.nl
www.kiwa.nl



2017180234

Supplier

Appendagefabriek Kolk B.V.
Parelstraat 5
7554 TL HENGEL O V
Tel. 074-2918961
Fax 074-2436734
office@kolkbv.nl
www.kolkbv.nl

Certification process
consists of initial and
regular assessment of:

- quality system
- product

Gate valves and butterfly valves

PRODUCT SPECIFICATION

The products mentioned below belong to this technical approval-with-product certificate

Gate valves

Model : EKO, Sunaflex T8193, 2500 cycli endurance

PN 10	PN 16	PN: 10/16
DN 50	DN 200	DN 200
DN 65	DN 250	DN 250
DN 80	DN 300	DN 300
DN 100	DN 350	DN 350
DN 125	DN 400	DN 400
DN 150	DN 450	DN 450
	DN 500	DN 500
	DN 600	DN 600

Butterfly valves

Model : EKK, Sunaflex T8165, 2500 cycli endurance

PN 10	PN 16	PN: 10/16
DN 200	DN 200	DN 100
DN 250	DN 250	DN 125
DN 350	DN 350	DN 150
DN 400	DN 400	
DN 450	DN 450	
DN 500	DN 500	
DN 600	DN 600	
DN 600	DN 600	
DN 700	DN 700	
DN 800	DN 800	
DN 900	DN 900	
DN 1000	DN 1000	
DN 1100	DN 1100	
DN 1200	DN 1200	
DN 1300	DN 1300	
DN 1400	DN 1400	

Gate valves and butterfly valves

Fitness for contact with drinking water

This product is approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" ("Materials and chemicals in the supply of drinking water and warm tap water Regulation"; published in the Government Gazette).

These hygienic aspects are based on two main criteria. The product shall permanently comply with:

- The product recipe approved during the assessment procedure. This recipe is not to be changed without prior approval by Kiwa according to the Kiwa approval procedure for the hygienic aspects;
- Specific product requirements for the hygienic aspects.

The recipe and specific product requirements are laid down in the for confidentiality reasons undisclosed 'appendix hygienic aspects' to this certificate.

MARKING

The Kiwa[®]-mark products are marked with the word mark "KIWA 

Place of the mark: on the body or identification plate

Compulsory specifications:

- name or mark of manufacturer: on the body or specification plate;
- identification of the shell material(s): on the body or specification plate;
- nominal size "DN ...": on the body or specification plate;
- nominal working pressure "PN ...": on the body or specification plate;
- identification of the year of manufacture: on the body or specification plate;
- number of the relevant part of the EN1074: on the body or specification plate.

Remark:

- the marking may be applied also to the identification plate;
- the word mark Kiwa and the name or mark of the manufacturer shall be at minimum on the identification plate.

Method of marking:

- Non-erasable;
- visible after assembly.

APPLICATION AND USE

Gate valves are designed to, both underground as over ground, be used in pipes for drinking water or raw material for drinking water, with a maximum medium temperature of 30 °C. The valves are designed to open or shut off the pipes and not for regulation purposes.

RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Appendagefabriek Kolk B.V.
- and, if necessary,
- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.